

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3175-1539:100 Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: Filtration Group Inc., 912 E. Washington St., Joliet, IL 60433
Contact: *Joseph Benoit (815) 774-1289 Fax (815) 726-2765

DESIGN: Model "Pocket Filter" and "Polymax" pocket filter dry type, throw-away air filter units. A maximum of 12 pockets, made of glass fiber or synthetic media and is containing eight stitch lines per pocket are secured to a metal pocket retainer with adhesive or staples. A maximum of 12 pockets are installed in a metal header frame secured by a rivet. The pockets are stapled or crimped together and the seam may be covered with a metal clip. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Class I and II
Maximum depth: 36"

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as Class I and II, dry type throw-away pocket air filter units for use in heating, ventilating, and air conditioning systems.

*Rev. 06-21-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager